

UNOFFICIAL COPY

527 CMR BOARD OF FIRE PREVENTION REGULATIONS

527 1.03(9) Fire Protection Devices Neither Designed Nor Capable of Function. Any device or object that reasonable appears to be a smoke detector, sprinkler head, carbon monoxide alarm, heat detector or any other similar device, used for life safety or fire protection that is, in fact, neither designed nor capable or performing such life safety or fire protection function, shall be prohibited.